

HUNTINGTON MEMORIAL LIBRARY BOARD OF TRUSTEES  
For: HUNTINGTON PARK  
**Contract EPF 181 932**

**Clarification #1**

**Response to Request for Information regarding the Huntington Park project: (below in red)**

1. *What seed mix # from Ernst is to be used for MX Steep Slope Wild Flower and Seed mix and W4 Wild Flower Mix?*

MX: This mix is to be a combination of two seed mixes applied in separate applications:

-Seed mix 1: 'Three-Way Tall Fescue Mix – ERNMX-136' or approved equal. Seeding rate: 7-10lb / 1,000SF.

-Seed mix 2: Custom blend by Ernst (see image below). Seeding rate: 1/2lb / 1,000SF. Please note: this seed mix to be applied over the fescue blend; seed separately (do not mix by hand). Preferred method of install: hydroseeding (if hydroseeding, apply each mix separately by hand, then spray hydromulch on top).

2. *What size are the stone pavers supposed to be?*

Please refer to L2.0 and DTL 5/L6.0 for paver sizes. Per L2.0 Paver courses shall be 9" and 1'-0" wide. Per DTL 5/L6.0, pavers 9" wide shall be 1'-6" long, TYP; pavers 1'-0" wide shall be 2'-0" long, typ. Per DTL 5/L6.0, paver joints shall misalign by 4" min. Paver lengths shall be trimmed as necessary to achieve this intent.